



"RE-BUILDING THE CITY'S WATER SYSTEMS FOR THE 21ST CENTURY"

Sewerage & Water Board of NEW ORLEANS

625 ST. JOSEPH STREET
NEW ORLEANS, LA 70165 • 504-529-2837 OR 52-WATER
www.swbno.org

July 8, 2021

Addendum No. 1

Your reference is directed to **Proposal Req Number: AL210017** for Furnishing Lime for the Sewerage and Water Board of New Orleans which is scheduled to open at **11:00 a.m. CST** on **July 15, 2021** for SWBNO Water Purification.

This addendum includes a question.

Question

1) My company provides lime slurries and related products for water treatment. As part of this bid, would lime slurries be considered? If not, would you or the technical team consider our product Lime Cure as an additive in the slaking process? This product helps reduce scaling and improves lime use overall.

Lime slurries will not be considered. The Sewerage and Water Board will accept bids only from vendors or manufacturers whose Lime conforms to AWWA Standard B202-13. The Lime must also be certified as suitable for the treatment of drinking water by an accredited certification organization in accordance with ANSI/NSF Standard 60, Drinking Water Treatment Chemicals-Health Effects. Verification of NSF Standard 60 certification must also be included within the completed bid package.

This addendum consists of one (1) page.

*** END OF ADDENDUM ***